



Growing Communities One Family At A Time

ADDENDUM No. 2

March 10, 2026

HUNTSVILLE HOUSING AUTHORITY

**QUOTATION FOR SMALL PURCHASE (QSP)
QSP NO. 2026-02
SECURITY STORM DOORS
(SEARCY)**

This addendum to subject QSP is a result of a request on March 9, 2026

Question: Under the panel options you listed (solid steel, expanded metal, or perforated steel), would you consider .028 stainless steel security screen as an alternative to the perforated steel panel? This option provides strong visibility and ventilation while maintaining durability and corrosion resistance for exterior applications.

Answer: *Based on the Brookside SOW, we would not consider .028 stainless steel security screen to be an automatic equivalent to the specified steel door construction. The SOW requires insulated steel or fiberglass exterior doors, with steel doors meeting a minimum 20-gauge requirement. If you would like to propose the stainless security screen option as an alternate, please provide full product specifications for HHA review and approval.*

Question: Is reversible handing required, or would a factory-designated left- or right-hand door be acceptable? In many installations, fixed handing can simplify installation and improve overall fit and performance.

Answer: *Based on the Brookside SOW, reversible handing is not specifically required. Factory-designated left-hand or right-hand doors are acceptable, provided the handing matches the existing openings verified during the contractor's site inspection and the doors meet all other project specifications.*

This addendum forms a part of the Contract Documents and modifies the original QSP. All terms and conditions in the original QSP dated February 26, 2026 remains the same.

Additionally, your submitted response shall acknowledge the receipt of this Addendum on the form of Bid.